



System IWK

Synchronization with a fundamental frequency of 50/60 Hz depending on option according to ICE 61000-4-30 and version of the IWK-hardware

	Version of the IWK-Hardware @file (IWKHard.ini)	Option to ICE 61000-4-30	50 Hz Software	50 Hz Hardware PLL	60 Hz Software	60 Hz Hardware PLL
1	VerOhneFreq	Yes	Yes	No	Yes	No
2		No	Yes	No	Yes	No
3	VerBis2012	Yes	Yes	Yes	Yes	No
4		No	Yes	Yes	Yes	No
5	Ver2012_1	Yes	Yes	Yes	Yes	No
6		No	Yes	Yes	Yes	No
7	Ver2014	Yes	Yes	Yes	Yes	No
8		No	Yes	Yes	Yes	Yes